







In creating the modern, aesthetically pleasing and ergonomic design of the CURVA range we did not lose sight of the need to produce a true value for money product offering the upmost appeal to installers and end users alike.

Only the best quality raw materials were used in producing this durable, attractive and modern range of accessories which will adorn the walls of all manner of buildings for years to come.

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com





Product Range		
20A Control Switches With Flex Outlet (Through Bottom)		
CCA022	20A Double Pole Switch	
CCA023	20A Double Pole Switch with Neon	
CCA040	20A Double Pole Switch 'Water Heater'	
CCA042	20A Double Pole Switch with Neon 'Water Heater'	

#### 20A Sink Bath Switch

CCA024 20A Double Pole Sink Bath Switch with Neon







CCA022 CCA023 CCA024





CCA040 CCA042

Errors & Omissions excluded. Specification is subject to change without notice.

V1.


Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

**Telephone:** 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com





## **Product Dimensional Drawings (mm)**



Errors & Omissions excluded. Specification is subject to change without notice.

V1.0


Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB


**Telephone:** 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com





## **Wiring Diagrams**





**Facsimile:** 01827 63362

Website: www.scolmore.com





Technical Specification		
20A Control Switches		
Material Composition	Front Plate, Rocker Switch & Rear Housing: Urea	
	Terminals: Brass	
	Terminal Screws: Steel & Yellow Passivated	
	Internal Mechanism: Formed Press Brass	
	Silver "on-lay" Copper / Brass Contacts	
Voltage	240V~ 50Hz	
Current Rating	20A	
Terminal Size	5mm ø	
<b>Torque Value</b>	1.8Nm	
Cable Size	4 x 2.5mm <sup>2</sup>	
Double Pole	Yes	
Twin Earth	Yes	
Back Box Depth	25mm - 47mm	
Warranty	10 Years	
Anti Microbial Certified	Yes	
IP Rating	IP20	
<b>Operational Temperature</b>	-5° to +40°C	
Standards	The Low Voltage Directive 2006/95/EC	
	BS EN 60669-1:1999 + A1:2002 + A2:2008	
	Modified ISO 22196	

#### **Additional Information**

Ensure that the mains supply is isolated before commencing installation and refer to the circuit diagram with the relevant product.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal.

All white moulded accessories are manufactured using Urea Formaldehyde, which has similar inherent properties to antimicrobial additives that inhibit the growth of infectious diseases. All products were independently tested and achieved a 99.9% kill rate across all four types of the strains of bacteria - MRSA, E-Coli, Salmonella, and Klebsiella Pneumoniae.

Errors & Omissions excluded. Specification is subject to change without notice

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

**Telephone:** 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com



# **Scolmore**

#### **Scolmore International Ltd**

1 Scolmore Park: Landsberg Lichfield Road Industrial Estate Tamworth, Staffordshire B79 7XB

t: 01827 63454 f: 01827 63362

e: sales@scolmore.com w: www.scolmore.com

## **DECLARATION OF CONFORMITY**

1. Issuer Name Scolmore International Limited

2. Issuer Address 1 Scolmore Park, Landsberg,

Lichfield Road Industrial Estate, Tamworth, Staffordshire, B79 7XB

3. Object(s) of Declaration Curva Range

a. *Group* 20A Control Switches

b. Model No. CCA022, CCA023, CCA024, CCA040, CCA042

4. The object of the declaration described above is in conformity with the requirements of the following Legislations:

Document No Title

2006/95/EC Low Voltage Directive

5. All products contained within the aforementioned comply with the relevant standards and requirements listed below.

EN 60669-1:1999 + A1:2002 + A2:2008

6. I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008

Signed, for and on behalf of: Scolmore International Limited

8 setto

Steven Bettson BSc - Senior Technical Support Engineer

**CE13** 







